



VALVE BOX WILL BE SET $\frac{1}{2}$ " BELOW PAVEMENT AND FLUSH (AT GRADE) IN TURF AND SIDEWALK AREAS

COVER WILL BE MARKED "WATER"




VALVE BOX WILL BE SET TO HAVE 6" ADJUSTMENT UP AND DOWN FROM FINISHED GRADE



VALVE BOX WILL BE TYLER-UNION 6860-G SERIES OR APPROVED EQUAL, SCREW TYPE

GATE VALVE ADAPTOR AS MANUFACTURED BY ADAPTOR INC., OR APPROVED EQUAL (SEE INSET A)

VALVE SIZE	DIMENSION "A"
6"	10"
8"	14"



CITY OF BURNSVILLE - ENGINEERING DEPT.

VALVE BOX INSTALLATION

Plate No.

WM-6

Revision Date

3/2019

File Location:

S:\Details\english\Watermain\WM06-Valve Box.dwg